

ADDENDUM NO. 2

For The

WASHINGTON STREET SIDEWALK AND LIGHTING IMPROVEMENTS

May 31, 2016

Item No. 1

There are two alternate fixture and pole manufacturers to be included as equals to the specified fixture and pole schedule shown on Drawing E-1 for bidders as follows:

Fixture Type A LUMEC # S56C2-80W48LED4K-R-GL-LE3-UNIV-SFOK-FN1-BKTX with
Union Metal # P1571-70-B231-Y2

Fixture Type A STERNBERG # G773 /991/XRLED 12L 35 T3 MDL21
with # 6212 FP5 BK BKY COUPLINGS/ SKIRT / LP-GFI-IUC / TOP OF
POLE

Note, the base may need to be slightly larger in diameter, depending on which pole is provided. One of the above vendors has a 14" bolt circle, and therefore, the diameter of the base will need to be 26" in diameter versus 24" in diameter. The cost for such difference shall be included in the unit price per each installed.

Item No. 2

Liquidated damages for the subject project shall be \$100.00 per day. Sections 00400 and 00500 of the Specifications shall reflect the subsequent change.

Item No. 3

Funding for the subject project will be provided by the City of Perry. Section 00200 of the Specifications shall reflect the subsequent change.

Item No. 4

Electrical wiring from light poles designated as S1-A, S2-A, and S3-A on Drawing No. E-2 shall be horizontally directional drilled (HDD) from location to location, not trenched. The change in quantities of trenching and HDD will be handled in Section 00400, Proposal, in Addendum No. 3.


Engineer of Record

May 31, 2016 _____

Date

